

TEST REPORT

Lucideon Reference: 182262 (QT-50274/1/GMB)/Ref. 3

Project Title: Testing of Pure Vista MegaGrip Balustrade System Incorporating 35.7 mm Romag Bullet Resistant Glass in Accordance with BS 6180:2011

Client: Pure Vista Ltd
Pendewey
Stony Lane
Bodmin
Cornwall
PL31 2QX

For the Attention of: Mr Adam Oakes & Mr Mark Oakes

Author(s): Miss Lisa Cobden

Report Date: 31 May, 2018

Purchase Order No.: 2089

Work Location: Lucideon UK



Mr Justin Fryer
Consultancy Team
Reviewer



Miss Lisa Cobden
Consultancy Team
Project Manager



CONTENTS

	Page
1 INTRODUCTION	3
2 TEST SAMPLES	3
3 TEST PROGRAMME	3
4 TEST PREPARATION	3
5 TEST METHOD	3
6 RESULTS	4
TABLES	5-6
PLATE	7
CHART	8

1 INTRODUCTION

Lucideon Limited were commissioned by the client, Pure Vista Ltd, to carry out load testing in accordance with BS 6180:2011 Barriers in and about buildings, to allow their balustrade system to be classified for use in accordance with the Code of Practice included within the standard.

The testing was carried out at Lucideon's facilities at Queens Road, Penkhull, Stoke on Trent.

This report summarises the test results obtained during the test programme and does not provide interpretation of those results.

2 TEST SAMPLES

The system tested was designated as follows:

- MegaGrip.

The system had been designed and intended to be used as the base mount for free standing balustrades. The systems and glass were installed by Pure Vista personnel.

3 TEST PROGRAMME

A horizontal line load was applied to the system using the following glazed sections:

- 35.7 mm Romag Bullet Resistant Glass

4 TEST PREPARATION

The channel was bolted to the top of a concrete block, which in turn was fixed to the floor of the test facility.

The 1.0 m length of channel was bolted to the block at 200 mm centres, 100 mm from the end and 200 mm thereafter. The clamps were installed at 4 clamps per meter, spaced at 100 mm from the edge with 200 mm between clamps.

5 TEST METHOD

A horizontal imposed line load was applied to the glass at a height of 1400 mm, 1500 mm and 1800 mm above the datum level of the floor and the deflection of the panel was measured at the point of the applied load. The load was applied via a hydraulic ram and the deflection measured using a linear voltage displacement transducer (see Plates 1).



6 RESULTS

The test was carried out in accordance with the guidance given in BS 6180 Barriers in and about buildings – Code of Practice. The standard states that the maximum allowable deflection for a free standing glass protective barrier when loaded at 1100 is 25 mm. The client requested a more arduous test with the barrier loaded at 1400 mm, 1500 mm, and 1800 mm.

Table 2 of BS 6180 Barriers in and about buildings – Code of Practice categorises parapets, barriers and balustrades for areas of use depending on the loads they have achieved under testing.

The loads achieved by the Pure Vista system tested under horizontal imposed line load to the maximum deflection of 25 mm are given in Table 1. All figures quoted in the Tables contain no safety factors and are direct loads as achieved by the system under test conditions.

Table 2 summarise the suitability of the tested systems in accordance with Table 2 of BS 6180:2011.



TABLES

Table 1 - Summary of Performance of Pure Vista MegaGrip Balustrade System Base Mounted into Concrete Tested under Horizontal Imposed Line Load

Glass Span (mm)	Glass Type	Test Height (mm)	Imposed Line Load at 25 mm Deflection (kN/m)	Working Line Load for System (kN/m)	Deflection at Working Line Load for System (mm)
1000	35.7 mm Romag	1400	1.79	1.50	19.18
1000	35.7 mm Romag	1500	1.41	0.74	11.68
1000	35.7 mm Romag	1800	0.93	0.74	20.18

Table 2 - Summary of Suitability of Pure Vista MegaGrip Base Mounted into Concrete in Accordance with Table 2 of BS 6180:2011

Type of Occupancy for Part of the Building	Examples of Specific Use	Horizontal Uniformly Distributed Line Load (kN/m)	MegaGrip		
			35.7 mm Romag Glass at 1400 mm	35.7 mm Romag Glass at 1500 mm	35.7 mm Romag Glass at 1800 mm
Domestic and residential activities	(i) all areas within or serving exclusively one single family dwelling including stairs, landings, etc. but excluding external balconies and edges of roofs	0.36	✓	✓	✓
	(ii) other residential, i.e. houses of multiple occupancy and balconies, including Juliette balconies and edges of roofs in single family dwellings	0.74	✓	✓	✓
Offices and work areas not included elsewhere, including storage areas	(iii) light access stairs and gangways not more than 600 mm wide	0.22	✓	✓	✓
	(iv) light pedestrian traffic routes in industrial and storage buildings except designated escape routes	0.36	✓	✓	✓
	(v) areas not susceptible to overcrowding in office and institutional buildings, also industrial and storage buildings except as given above	0.74	✓	✓	✓
Areas where people might congregate	(vi) areas having fixed seating within 530 mm of the barrier, balustrade or parapet	1.50	✓	X	X

Type of Occupancy for Part of the Building	Examples of Specific Use	Horizontal Uniformly Distributed Line Load (kN/m)	MegaGrip		
			35.7 mm Romag Glass at 1400 mm	35.7 mm Romag Glass at 1500 mm	35.7 mm Romag Glass at 1800 mm
Areas with tables or fixed seating	(vii) restaurants and bars	1.50	✓	X	X
Areas without obstacles for moving people and not susceptible to overcrowding	(viii) stairs, landings corridors ramps	0.74	✓	✓	✓
	(ix) external balconies including Juliette balconies and edges of roofs; footways and pavements within building cartilage adjacent to basement/sunken areas	0.74	✓	✓	✓
Areas susceptible to overcrowding	(x) footways or pavements less than 3 m wide adjacent to sunken areas	1.50	✓	X	X
	(xi) theatres, cinemas, discotheques, bars, auditoria, shopping malls, assembly areas, studios; footways or pavements greater than 3 m wide adjacent to sunken areas	3.00	X	X	X
	(xii) grandstands and stadia	(Note 1)	-	-	-
Retail areas	(xiii) all retail areas including public areas of banks/building societies or betting shops	1.50	✓	X	X
Vehicular	(xiv) pedestrian areas in car parks, including stairs, landings, ramps, edges of internal floors, footways, edges of roofs	1.50 (Note 2)	✓	X	X
	(xv) horizontal loads imposed by vehicles	(Note 2)	-	-	-

NOTE: The results given in this report apply only to the samples that have been tested.

END OF REPORT

PLATE



Plate 1 - Generic Test Configuration

Chart 1 - Load Deflection Curve for Pure Vista MegaGrip System Incorporating 35.7 mm Romag Glass Fixed into Concrete

Test Report: 182262/Ref.3

